



**MATERIAL STANDARD****BRACKET ASSEMBLY  
CROSSARM MOUNTED CUTOUT FOR CONTAMINATED AREAS**

**Note:** Bracket is intended to secure station insulator (Stock No. 690187) to a 10 foot, 6 pin crossarm (Stock No. 540146).

**Insulator Support Bracket Stock No.:**  
563228

**Material:** 1/4" mild steel plate

**Surface preparation:** Hot dip galvanized per ASTM A153

**Material List**

| Item | Qty | Description   | Stock No. |
|------|-----|---|-----------|
| 1    | 1   | Bracket, Cutout Mounting, Material. Standard 5632.2 | 563224    |
| 2    | 1   | Insulator, Station Post                             | 690187    |
| 3    | 8   | Screw, Hex Head Cap, 1/2" - 13NC x 1"               | 784825    |
| 4    | 8   | Lock Washer, 1/2", Galvanized                       | 584255    |
| 5    | 2   | Bolt, 5/8" x 6", Machine, Galvanized                | 780836    |
| 6    | 1   | Insulator Support Plate (shop made, this spec)      | 563228    |
| 7    | 1   | Backing Plate (shop made, this spec)                |           |
| 8    | 2   | Lock Washer, 5/8"                                   | 788156    |

**Stock Unit:** EA

**Assembly Stock No.:** 563227 (includes all of the items in the Material List)

| ORIGINATOR         | STANDARDS COORDINATOR     | STANDARDS SUPERVISOR    | UNIT DIRECTOR        |
|--------------------|---------------------------|-------------------------|----------------------|
| <i>Jim S. Horn</i> | <i>Charles L. Shaffer</i> | <i>John C. Schinner</i> | <i>Harold J. Jry</i> |